






# PEM735 measuring case checklist


## 1. Preparing the measuring task

### Connecting the case

Task	Done?
<b>The case is switched off.</b>	<input type="checkbox"/>
The <b>jumper wires</b> for all current sensors are placed correctly	<input type="checkbox"/>
<b>Connections that are not in use are short-circuited</b>	<input type="checkbox"/>
All current sensors have <b>first</b> been connected <b>to the case</b> and then to the load	<input type="checkbox"/>
The measuring ranges of the Rogowski repeaters are set as expected	<input type="checkbox"/>
Compensation setting checked on repeater. For included Rogowskis: 600 mm	<input type="checkbox"/>
<b>Voltage measuring taps</b> connected according to measuring case manual:  Connect the measuring voltage cables to the corresponding socket L1...3/N/PE at the side of the case. To connect the secured side of the measuring voltage cable you have the following options: <ul style="list-style-type: none"><li>– Crocodile clips (PE always, for other cables optional)</li><li>– Safety crocodile clips for use with push-wire terminals</li><li>– Magnetic test probes to enable the screws to make contact with the circuit breaker</li></ul>	<input type="checkbox"/>
The <b>digital inputs/outputs</b> are wired if required	<input type="checkbox"/>
Switch on the case	<input type="checkbox"/>
If required: Make network settings for/via WLAN or LAN (router and PEM735 display)	<input type="checkbox"/>



## PEM735 basic settings (web server "Settings device")


Task	Done?																								
Star or delta set correctly	<input type="checkbox"/>																								
<p>Clockwise rotating field tested by means of voltage unbalance (phasor diagram; an anti-clockwise rotating field has a very high voltage unbalance)</p> <div><div><div>EN 50 160 REPORT</div><div>MEASURED VALUE</div><div>RECORDER</div><div>EVENTS</div><div>SETPOINT-RECORDER-MATRIX</div><div>SETTINGS TRIGGER</div><div>SETTINGS RECORDER</div><div>SETTINGS DEVICE</div></div><div><table><thead><tr><th>Name</th><th>L1</th><th>L2</th><th>L3</th></tr></thead><tbody><tr><td>U</td><td>230.16 V</td><td>230.73 V</td><td>229.57 V</td></tr><tr><td>I</td><td>5.00 A</td><td>5.01 A</td><td>4.99 A</td></tr><tr><td><math>\varphi</math> U</td><td>0 °</td><td>240.14 °</td><td>119.99 °</td></tr><tr><td><math>\varphi</math> I</td><td>2.61 °</td><td>241.56 °</td><td>122.04 °</td></tr><tr><td><math>\varphi</math> U-<math>\varphi</math> I</td><td>-2.61 °</td><td>-1.42 °</td><td>-2.05 °</td></tr></tbody></table><p>Unbalance voltage: 0.13 % Unbalance current: 0.65 % Frequency: 50.00 Hz</p></div></div>	Name	L1	L2	L3	U	230.16 V	230.73 V	229.57 V	I	5.00 A	5.01 A	4.99 A	$\varphi$ U	0 °	240.14 °	119.99 °	$\varphi$ I	2.61 °	241.56 °	122.04 °	$\varphi$ U- $\varphi$ I	-2.61 °	-1.42 °	-2.05 °	<input type="checkbox"/>
Name	L1	L2	L3																						
U	230.16 V	230.73 V	229.57 V																						
I	5.00 A	5.01 A	4.99 A																						
$\varphi$ U	0 °	240.14 °	119.99 °																						
$\varphi$ I	2.61 °	241.56 °	122.04 °																						
$\varphi$ U- $\varphi$ I	-2.61 °	-1.42 °	-2.05 °																						
<p>PTs and CTs for phases L1, L2 and L3 set correctly according to measuring case manual: Rogowski and C112: secondary 1 A C148: secondary 5 A</p>	<input type="checkbox"/>																								
<p>PTs and CTs for U4 and I4 set correctly according to measuring case manual</p>	<input type="checkbox"/>																								
<p>Correct <b>polarity for the current transformers</b>: Test on display via menu "Waveform".</p> <div><div><p>Example phase L1: Current and voltage are in phase: Energy is absorbed (<b>energy import</b>).</p><p>If <math>\cos \varphi</math> is not equal to 1, the figure may deviate slightly (additional slight phase displacement)</p></div></div>	<input type="checkbox"/>																								
<div><div><p>Example phase L1: Current and voltage are out of phase: Energy is released (<b>energy export</b>)</p><p><b>PEM735 operates in the load meter arrow system.</b></p><p>If <math>\cos \varphi</math> is not equal to 1, the figure may deviate slightly (additional slight phase displacement)</p></div></div>	<input type="checkbox"/>																								

Task	Done?
Plausibility check measuring range of the Rogowski transformers (with current measuring clamp)	<input type="checkbox"/>
<b>Nominal system voltage</b> (as phase-to-phase voltage) set correctly 	<input type="checkbox"/>
<b>Nominal frequency</b> set correctly	<input type="checkbox"/>
Calculation of <b>power factor</b> set according to IEC	<input type="checkbox"/>
Vectorial calculation of the <b>apparent power</b> set	<input type="checkbox"/>
Calculation of <b>distortion factor</b> set as % of the fundamental component	<input type="checkbox"/>
Calculation of <b>harmonics</b> set as subgroup	<input type="checkbox"/>
Max. <b>harmonics order</b> for calculation of THD, TEHD, TOHD = <b>40</b> set	<input type="checkbox"/>
<b>Flicker mode</b> set correctly (usually 230 V)	<input type="checkbox"/>
Frequencies for the <b>mains signalling transmission voltages</b> set, in case they are recorded	<input type="checkbox"/>
<b>Start day</b> for the EN 50160 report interval set (usually to the next weekday)	<input type="checkbox"/>
<b>Time</b> and <b>time zone</b> set correctly	<input type="checkbox"/>

## Settings for recorders/setpoints

Task	Done?																											
<div><div><div>MEASURED VALUE</div><div>RECORDER</div><div>EVENTS</div><div>SETPOINT-RECORDER-MATRIX</div><div>SETTINGS TRIGGER</div><div>STANDARD SETPOINTS</div><div>HIGH-SPEED SETPOINTS</div><div>SAG/SWELL</div><div>TRANSIENTS</div><div>RAPID VOLTAGE CHANGES</div><div>SETTINGS RECORDER</div><div>SETTINGS DEVICE</div></div><div><table><thead><tr><th>Parameter</th><th>Previous parameters</th><th>Parameter after</th></tr></thead><tbody><tr><td>Sag/Swell Monitoring</td><td>on</td><td>on</td></tr><tr><td>Voltage reference</td><td>Nominal voltage</td><td>Nominal voltage</td></tr><tr><td>Limit Overvoltage [101..200] %</td><td>110 %</td><td>110</td></tr><tr><td>Hysteresis Overvoltage [0.1..100] %</td><td>0.5 %</td><td>0,5</td></tr><tr><td>Limit Undervoltage [1..99] %</td><td>90 %</td><td>90</td></tr><tr><td>Hysteresis Undervoltage [0.1..100] %</td><td>0.5 %</td><td>0,5</td></tr><tr><td>Interruption Voltage Limit [0..50] %</td><td>20 %</td><td>20</td></tr><tr><td>Interruption Voltage Hysteresis [0.1..100] %</td><td>0.5 %</td><td>0,5</td></tr></tbody></table></div></div>	Parameter	Previous parameters	Parameter after	Sag/Swell Monitoring	on	on	Voltage reference	Nominal voltage	Nominal voltage	Limit Overvoltage [101..200] %	110 %	110	Hysteresis Overvoltage [0.1..100] %	0.5 %	0,5	Limit Undervoltage [1..99] %	90 %	90	Hysteresis Undervoltage [0.1..100] %	0.5 %	0,5	Interruption Voltage Limit [0..50] %	20 %	20	Interruption Voltage Hysteresis [0.1..100] %	0.5 %	0,5	<div></div>
Parameter	Previous parameters	Parameter after																										
Sag/Swell Monitoring	on	on																										
Voltage reference	Nominal voltage	Nominal voltage																										
Limit Overvoltage [101..200] %	110 %	110																										
Hysteresis Overvoltage [0.1..100] %	0.5 %	0,5																										
Limit Undervoltage [1..99] %	90 %	90																										
Hysteresis Undervoltage [0.1..100] %	0.5 %	0,5																										
Interruption Voltage Limit [0..50] %	20 %	20																										
Interruption Voltage Hysteresis [0.1..100] %	0.5 %	0,5																										
The <b>reference voltage</b> is set to "Nominal voltage"																												
The response value <b>overvoltage</b> is not higher than 110 %																												
The response value <b>undervoltage</b> is not lower than 90 %																												
The trigger is set to a (high-speed) <b>data recorder</b> that contains all relevant measuring quantities for sags/swells or failures. This recorder is configured as "Triggered by = digital setpoint"																												

Task	Done?
<p><b>Transients: Monitoring of transients set to "On"</b></p> 	<input type="checkbox"/>
Both triggers are set to different waveform recorders	<input type="checkbox"/>
<p><b>Rapid voltage changes: Monitoring set to "On"</b></p> 	<input type="checkbox"/>
Trigger is configured as required, e.g. standard or high-speed recorder	<input type="checkbox"/>
Depending on measuring task: Additional (high-speed) setpoints have been defined independently.	<input type="checkbox"/>

Task	Done?
<b>Data recorder 1 and 2</b> <ul style="list-style-type: none"> <li>– Triggered by timer</li> <li>– Overwriting: No</li> <li>– Data points: 65535</li> <li>– Interval: 15</li> <li>– Delay: 0</li> </ul> Parameters: All currents, voltages, power, frequency, power factors (split between both recorders)	<input type="checkbox"/>
<b>Data recorder 3</b> As data recorder 1, but <ul style="list-style-type: none"> <li>– Interval: 900 (= 15 minutes)</li> </ul> Parameters: All requirements parameters, all PST, maybe also energies	<input type="checkbox"/>
Additional data recorders at your own discretion, depending on what data are to be recorded when triggering the various setpoints	<input type="checkbox"/>
<b>Waveform recorder 1</b> 20 cycles per recording <b>Waveform recorder 2</b> 640 cycles per recording  	<input type="checkbox"/>
Test <b>setpoint recorder matrix</b> : Each trigger is assigned to a recorder/relay, configuration errors are not signalled	<input type="checkbox"/>
All <b>delete functions</b> available at "Settings device" have been carried out	<input type="checkbox"/>
An adequate number of <b>photos</b> have been taken during assembly for documentation purposes	<input type="checkbox"/>

Date

Signature

## 2. Follow-up of a measuring task

### Device backup

Task	Done?
<p>All used <b>standard and high-speed recorders</b>, including those configured as a timer, are called one after another  <b>These are not included in the setpoint recorder matrix!</b></p> <p><i>Click on "All" on each recorder when it is called the first time.          Afterwards, save the data locally as a *.csv file by clicking on "Export".</i></p>	<input type="checkbox"/>
<p>All <b>waveform recorder</b> recordings are called one after another and saved via a screenshot</p> <p><i>Buttons &lt;Ctrl&gt; + &lt;Alt&gt; + &lt;Print Screen&gt;, paste clipboard content to a word document or similar.          (The relevant parts can be zoomed in)</i></p>	<input type="checkbox"/>
Export <b>SOE log</b> as a *.csv file at "Events"	<input type="checkbox"/>
Export <b>PQ log</b> as a *.csv file at "Events"	<input type="checkbox"/>
Indicate all listed <b>EN 50160 reports</b> one after another (Print preview) and save them as PDF using a PDF creator or print them out using a printer	<input type="checkbox"/>

### Processing the data recorders

If there is a data recorder timestamp included in Excel, e.g. in cell "A2" as "Unix Time \* 1000" (also incl. ms), **the actual date + time** can be calculated in an additional column using the following formula:

**"=A2/86400000+25569+GMT/24",**

Number format = user-defined = "TT.MM.JJJJ hh:mm:ss,000" (high-speed recorder)  
 "TT.MM.JJJJ hh:mm:ss" (standard recorder).



**The timestamp of the data recorders does not take into account any time zone (GMT)!**  
 GMT = 1 (wintertime Germany)  
 GMT = 2 (summer time Germany)

\_\_\_\_\_  
 Date

\_\_\_\_\_  
 Signature

### 3. Resetting the case

Task	Done?
Network settings (for router and PEM735, IP address, subnet mask, gateway for each) set to the settings printed on the inside of the case	<input type="checkbox"/>
For the router: <ul style="list-style-type: none"> <li>– Encryption off</li> <li>– WLAN on</li> <li>– Router is access point</li> </ul>	<input type="checkbox"/>
All delete functions available at "Settings device" have been carried out	<input type="checkbox"/>
All setpoints and high-speed setpoints (except SAG/SWELL, transients and rapid voltage changes) are disconnected	<input type="checkbox"/>
All recorders and high-speed recorders are disconnected (also the ones with timer function, which are not included in the setpoint recorder matrix)	<input type="checkbox"/>

\_\_\_\_\_

Date

\_\_\_\_\_

Signature

Alle Rechte vorbehalten.  
Nachdruck und Vervielfältigung  
nur mit Genehmigung des Herausgebers.  
Änderungen vorbehalten!  
© Bender GmbH & Co. KG



All rights reserved.  
Reprinting and duplicating  
only with permission of the publisher.  
Subject to change!  
© Bender GmbH & Co. KG



Bender GmbH & Co. KG  
Londorfer Str. 65 • 35305 Grünberg • Germany  
Postfach 1161 • 35301 Grünberg • Germany

Tel.: +49 6401 807-0  
Fax: +49 6401 807-259

E-Mail: [info@bender.de](mailto:info@bender.de)  
Web: <http://www.bender.de>